



Florida Division of State Fire Marshal

The Florida Fire Marshals and Inspectors Association,
"Organization" (§633.026)

Informal Interpretation

Date: April 1, 2015

NFPA Document Number: 101

Edition: 5th Edition

Paragraph Reference: 30.3.4.1.1

For purpose of this petition, pertinent factors do not include the name of the governmental agency or persons representing that agency. Petitioners are discouraged from making any personal assertions about an agency or agency official. If this involves an actual situation, briefly explain all of the pertinent factors.

Actual Situation Explanation:

This involves a new 12 unit two story apartment building. The building will be equipped with fire sprinklers, supervised, and monitored. The upper 6 units share two sets of outside stairs.

Question (*should be worded so that it can be answered with either "Yes" or "No"*):

Does FS 633.202(13) exempt a 12 unit two story apartment from having a fire alarm with interior notification as required by FFPC 30.3.4.1.1

Answer: Yes

Reviewing Members:

Region 1: Bruce Teston
Region 2: John Gatlin
Region 3: James Groff
Region 4: Phil Gugliete
Region 5: Tony Apfelbeck
Region 6: Bob Salvaggio
Region 7: Bryan Parks

Committee Answer Submitted by,
Bryan Parks, Chairman
Informal Fire Code Interpretation Committee

Rulings herein expressed are not the formal position of the Florida State Fire Marshal's Office

3108 S.E. 21st Court | Okeechobee, FL 34974-6331 | Phone: (863) 467-8991 | Fax: (863) 467-8991

Website: www.FFMIA.org | Email: info@ffmia.org | http://www.myfloridacfo.com/sfm/bfpr/bfpr_index.htm